

CSIRO Verification Services Clayton, Victoria, Australia +61 (0)3 9545 2777 http://www.activfire.gov.au/

Certificate of Conformity

 Certificate num.
 Registration date
 Version
 Valid until

 afp - 2363
 8-Sep-2009
 Number Issue date 11 26-Apr-2019
 30-Apr-2020

Product designation

«ListingEntryText»

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

FireSense Pty Ltd

18-20 Brookhollow Avenue, BAULKHAM HILLS, NSW, AUSTRALIA, 2153

Registrant

Project Fire Products Limited

Pasturefields Lane Industrial Estate, HIXON, STAFFORDSHIRE, UNITED KINGDOM, ST15 8RR

Producer

Project Fire Products Limited

Pasturefields Lane Industrial Estate, HIXON, STAFFORDSHIRE, UNITED KINGDOM, ST15 8RR

Conformance criteria and evaluation

The Project Fire Products, Zonecheck MK-02, water flow switch tester has been evaluated and verified as conforming with the relevant requirements of the following criteria.

- 1. Factory Mutual Evaluation and approval, 'FM approval'.
- 2. Loss Prevention Council Evaluation, surveillance and approval, 'LPC approval'.
- 3. Underwriters Laboratories Evaluation and listing, 'UL listing'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

i. The pipe size and schedule of the Zonecheck system shall be identical to the size and schedule of the sprinkler system to which it is intended to be used in. The pipe size and schedule of the Zonecheck system shall also be compatible with the listing size and schedule of the waterflow indicator. This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices .and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker

Executive Officer - ActivFire Scheme





Schedule to

Certificate of Conformity

Certificate num.	Registration date	Version		Valid until		
afp - 2363	8-Sep-2009	Number 11	Issue date 26-Apr-2019	30-Apr-2020	Page 2 of 3	

Producer's description

The «ListingEntryText» are intended for installation in wet type sprinkler systems in either the horizontal or vertical position. The «ListingEntryText» consists of a recirculating pump, two sets of valves and elbows to facilitate the circulation of water, a System Sensor vane type water flow detector, and a key switch to activate the recirculating pump. When activated, the pump circulates the water within the sprinkler riser around the water flow detector to simulate the flow of one sprinkler head in operation.

Technical specification

The following details are a representative extract of the technical specification for the «ListingEntryText» and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Working pressure rating: 1210 kPa (175 psi)
Operating temperature range: 0°C to +49°C

Compatible pipe: 50 mm to 200 mm diameter

Manifold length: 650 mm

Component connections: 2 to 25 mm British Standard Thread elbows

Valves: Red - standard valve
Green - contains check valve

Pump operating voltages: 220 Vac, 0.88 A, 50 Hz

Key Switch:

Model: ZCK-1 (110 Vac)

ZCK-1E (220 Vac)

Principle components

Part ref.	Description	Designation		Size(s), nominal	Application
Z-507	Circulating pump	Wilo, Top S 25/7-PFE(Z)		240 Vac 50Hz	Assembled/retrofit
				120 Vac 60Hz	Assembled/retrofit
Z-510	Electronic diagnostic key	System Sensor,	ZCK-1	240 Vac 50Hz	Assembled/retrofit
	switch		ZCK-1E	120 Vac 60Hz	Assembled/retrofit
Z-505	Inlet valve c/s union tail	Cimberio CIM 357SFD-RED		25 mm	Assembled/retrofit
Z-506	Outlet isolating valve with NRV	Cimberio CIM 358V-Green		25 mm	Assembled/retrofit
Z-508	Water flow detectors	Potter,	VSR-F series	50 mm to 150 mm	Assembled
		System Sensor,	WFD20E	50 mm	Assembled
		System Sensor,	WFD25E	65 mm	Assembled
		System Sensor,	WFD30-2E	80 mm	Assembled
		System Sensor,	WFD40E	100 mm	Assembled
		System Sensor,	WFD60E	150 mm	Assembled
		System Sensor,	WFD080E	200 mm	Assembled
Z-501	Manifold	Grenville Engineering		650 mm long	
				x 50 mm dia.	Assembled
				x 65 mm dia.	Assembled
				x 80 mm dia.	Assembled
				x 100 mm dia.	Assembled
				x 150 mm dia.	Assembled
Z-513	Ballstop valve	Cimberio CIM 301/12 GMT ½" Yellow		15 mm	Assembled

LED operation:

Ready state: No LED

Test initiation: Green LED, 'PUMP'

Flow switch activation: Green LED, 'WATER-FLOW'

Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	
afp - 2363	8-Sep-2009	Number 11	Issue date 26-Apr-2019	30-Apr-2020	Page 3 of 3

Supplementary information

Manifold assembly:

The manifold assembly includes no less than two drain ports with the appropriate drain plugs. The manifold assembly comes with the pump, valves, elbows, pipe assembly, drain plugs and water flow detector pre-assembled.