



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 2261	12-Nov-2008	Number 22	Issue date 3-Apr-2026	30-Apr-2027

Page 1 of 3

Product designation

KAC, WCP5 series, weatherproof analogue manual call points

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Honeywell Security and Fire
9 Columbia Way, BAULKHAM HILLS, NSW, AUSTRALIA, 2153

Registrant

KAC Alarm Company
Z.A. La pièce 16 Rolle, Vaud, SWITZERLAND, CH-1180 ROLLE

Producer

Honeywell Life Safety Romania S.R.L.
Strada Salcâmului nr. 2 bis, LUGOJ, ROMANIA, 305500

Conformance criteria and evaluation

The KAC, WCP5 series, weatherproof analogue manual call points have been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 7240.11-2008, 'Fire detection and alarm systems - Part 11: Manual call points'.
2. European Standard EN 54-11(Type A):2001, 'Fire detection and fire alarm systems. Manual call points'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. Compatibility of this actuating device with new or existing control and indicating equipment should be verified prior to installation.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

Kaj Loh
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 2261	12-Nov-2008	Number 22	Issue date 3-Apr-2026	30-Apr-2027

Producer's description

The KAC, WCP5 series, weatherproof analogue manual call points consist of a square shaped housing within which is fitted a call point unit. The device is made up of a switch contact and the frangible element. Direct alarm activation is achieved by breaking the glass plate (frangible element) situated in the operating face of the unit or pushing the plastic resettable element. By replacing the frangible element a push button is setback into position and the device is returned to its quiescent state.

The addition of a waterproof enclosure to the range allows the unit to be used as a waterproof version (WCP). The waterproof models utilise the MCP mouldings which are mounted to the front of a waterproof enclosure. An IP67 rated switch is mounted on a plate in the front of the call point, and the cables are taken through into the waterproof enclosure and are sealed using a 2 part potting compound. Each WCP model uses the same PCB as for its respective MCP equivalent model. The PCB is mounted on the inside of the waterproof enclosure. The integral back box incorporates three 20mm threaded holes for cable gland fixing.

Additional description of outdoor addressable models:

WCP5 models

Red, Type A, addressable, break glass manual call point for outdoor use, incorporating System Sensor protocol, with the option of onboard isolation. Surface mounting only. There is a Honeywell protocol version, which is achieved by means of a resistor change on the PCB. The WCP can be converted to a resettable model by substituting the glass for a resettable frangible element. Terminations are made via a 4 way terminal plug.

WCP5A-RP01xx

System Sensor protocol.

(xx represents the characters used to indicate, surface or flush mount, glass or resettable element).

Technical specification

The following details are a representative extract of the technical specification for the KAC, WCP5 series, weatherproof analogue manual call points and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Schedule of properties/characteristics

The following schedule is an extract of physical and operational properties/characteristics of the certified/listed equipment.

Operating voltage:	15 to 30 Vdc (24 Vdc nominal)
Current consumption	
Quiescent, typical (Indoor)	385 μ A (LED off)
Quiescent, typical (Outdoor)	400 μ A (LED off)
Alarm, Indoor	7.8 mA
Alarm, Outdoor	7.6 mA
Protocols	CLIP (max 99 per SLC) FlashScan (max 159 per SLC)
Operating temperature range	
Indoor	-0° to 49° C
Outdoor	-25° to 70° C
Humidity	
Indoor	10% to 93%,
Outdoor	0% to 95%
Physical characteristics	
Dimensions	
Indoor Semi-Flush	93mm(h) x 89mm(w) x 27.5mm(d)
Indoor Surface	93mm(h) x 89mm(w) x 59.5mm(d)
Outdoor	93mm(h) x 97.5mm(w) x 71mm(d)
Colours	Red (Ral 3001), Yellow (Ral 1006), Green (Ral 6016), White (Ral 9010), Blue (Ral 5002)

Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 2261	12-Nov-2008	Number 22	Issue date 3-Apr-2026	30-Apr-2027

Page 3 of 3

Supplementary information

Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference		Title / description	Date issued (or date validated)	Source
Ident. type	Ident.			
Report	XF3031/R1	Evaluation for Conformity of the KAC WCP1, WCP2, WCP3, WCP4 and WCP5 Outdoor Use, Type A, Manual Call Point series to the requirements of AS 7240.11-2008	13-Apr-2017	CSIRO, Fire Systems Laboratory, AU
Report number	XF2407/R1	Verification of Conformity KAC Manual Call Points to EN 54: Part 11: 2001	30-Jun-2008	CSIRO, Industrial Research Services, AU
Datasheet	DOC-02-088:rev C	Notifier by Honeywell Manual Call Points NFX-MCP and WCP-5A	9-Oct-2014	Notifier Inertia, AU