

CSIRO Verification Services Clayton, Victoria, Australia +61 13 0036 3400 https://activfire.csiro.au

Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	
-f 2201	25.11 2000	Number	Issue date	22.4	Page 1 of 2
atp - 2381	25-Nov-2009	12	20-Apr-2022	30-Apr-2024	_

Product designation

Notifier, Model FSC-851AUS, multi criteria fire sensor

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Honeywell Security and Fire

9 Columbia Way, BAULKHAM HILLS, NSW, AUSTRALIA, 2153

Registrant

Honeywell Security and Fire

9 Columbia Way, BAULKHAM HILLS, NSW, AUSTRALIA, 2153

Producer

System Sensor Europe Javastrasse 2, Unit C2, Foundry Lane, HEGNAU, SWITZERLAND, CH-8604

Conformance criteria and evaluation

The Notifier, Model FSC-851AUS, multi criteria fire sensor has been evaluated and verified as conforming with the relevant requirements of the following criteria.

- 1. Australian Standard AS 7240.5-2004, 'Fire detection and alarm systems Part 5: Point type heat detectors (ISO 7240-5:2003, MOD)'.
- Australian Standard AS 7240.7-2004, 'Fire detection and alarm systems Part 7: Point-type smoke detectors using scattered light, transmitted light or ionization (ISO 7240-7:2003, MOD)'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. Installation and fitment of the detector using the Model B501 base.
- ii. The mode settings for advanced application are not used.
- iii. Installation of the detector is used in indoor dry environments,
- iv. Installation and maintenance as recommended by the supplier/manufacturer.
- v. Compatibility of this fire detector and its base assembly with new or existing control and indicating equipment should be verified prior to installation.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.



Kaj Loh

Executive Officer - ActivFire Scheme





Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	
afp - 2381	25-Nov-2009	Number 13	Issue date 20-Apr-2023	30-Apr-2024	Page 2 of 2

Producer's description

The Notifier, Model FSC-851AUS, multi criteria fire sensor is a microprocessor controlled, analogue addressable multi-sensor.

This fire detector incorporates four separate sensing elements. A carbon monoxide sensor (using an electrochemical cell), an infra red photo diode, a photoelectric smoke sensing chamber using the optical scatter principle and thermal detection using a thermistor.

The detector has six sensitivity settings which can be selected at the associated control and indicating equipment. Five sensitivity settings from least smoke sensitive to most smoke sensitive, each including heat operation, and one heat only setting in which the smoke sensing element is disabled.

The detector is a plug in sensor compatible with the Notifier, Model B501 detector base. Two LEDs on the sensor pulse as the detector is polled by the associated control and indicating equipment. These LEDs illuminate red to indicate the alarm status of the device.

The loop address of the device is set in the range from device 1 to device 159 using two rotary decade address switches on the rear of the detector.

The physical dimensions are 102 mm diameter and 60 mm high without base.

Technical specification

The following details are a representative extract of the technical specification for the Notifier, Model FSC-851AUS, multi criteria fire sensor and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Operating voltage range: 15 to 32 Vdc

Maximum average standby current: 300 μA (with LED blink enabled)

Alarm current: 7 mA @ 24 Vdc

Nominal activation temperature: $60 \, ^{\circ}\text{C}$ Operating temperature range: $-20 \text{ to } 55 \, ^{\circ}\text{C}$

Operating humidity range: 15 to 90 % RH, non-condensing

Construction: 102mm dia x 80mm high. 110g (with B501 base)

Tested base designation	Base + detector circuit type	
Notifier, Model B501	Analogue Addressable	