

# **PRODUCT DATA SHEET**

# SWIFT-GW Wireless Gateway

#### **FEATURES**

- ✓ Patented cascading wave mesh operation
- ✓ In the event that a communication path is interrupted, the SWIFT mesh system will use the redundant or backup communication path
- Any SWIFT device can be added to act as a repeater, eliminating the need for wired repeaters
- ✓ Support up to 50 devices: 1 wireless gateway and up to 49 SWIFT devices
- Multiple SWIFT wireless mesh networks can be installed on the same fire alarm control panel
- ✓ Up to 4 wireless networks can be installed with overlapping radio network coverage
- ✓ Site Survey feature
- ✓ SWIFT use a standard "code wheel" setting the SLC address
- ✓ SWIFT wireless devices use 4 lithium batteries with a battery life of approximately 2 years



#### **PRODUCT DESCRIPTION**

The SWIFT Wireless System can be applied in many situations that are problematic for traditional wired devices. In cases where areas of a building are difficult or impossible to wire, visually sensitive, or have restricted access, SWIFT wireless sensors provide an efficient, reliable solution. SWIFT wireless devices communicate with an AFP-3030 alarm system by means of a SWIFT Wireless Gateway. The SWIFT Gateway connects to the SLC loop of an AFP-3030 panel using FlashScan protocol. New type ID's for wireless devices are supported that allow the AFP-3030 to display all events such as alarms and fault indications, as well as unique fault conditions required for wireless devices.

Wireless devices in a SWIFT network develop "parent-child" communication links with other devices in the mesh, so that a message originating from a remote device "hops" to the closest parent device, and then to successive parent devices, until the message reaches the gateway. Alternate paths are also identified and supervised by the SWIFT protocol providing approved closed loop wireless communication. If a device does not have an established communication path with adequate signal strength, an additional device such as a wireless module may be installed in between so that it will act as a repeater.

A SWIFT Gateway system supports up to 50 devices: 1 SWIFT Gateway and up to 49 wireless detectors and monitor modules. The Gateway assumes one SLC address (module), and each wireless device assumes one module or detector address. The maximum number of gateways on a system is limited by the number of available SLC addresses on the AFP-3030, or a maximum of 4 gateways within common wireless range.

The SWIFT system has been designed so that it can be installed using only typical hand tools and magnets. However, the SWIFT Tools PC utility provides many benefits that can enhance the process of performing a site evaluation (Site Survey), installing a system (Mesh Configuration), or extracting detailed information from the system (Diagnostics). The utility runs on a Windows laptop and uses a USB radio antenna (SWIFT-USB) inserted into a USB slot to communicate with wireless devices within range of PC. Once devices have formed a mesh, the

NSW 18-20 Brookhollow Ave NORWEST 2153 02 8850 2888 sales@firesense.com.au VIC Unit 4, 297 Ingles St PORT MELBOURNE 3207 03 9646 4557 salesvic@firesense.com.au





SWIFT Tools can provide current information on all devices in the mesh as long as the PC is within range of the SWIFT Gateway.

The result is a fire system that combines both wires and wireless detection and presents all event information at the panel and/or network displays, when used.

#### SWIFT TOOLS

SWIFT Tools is a Windows PC-based utility that is used for site evaluation, system configuration and diagnostics. The SWIFT Tools program is used with the SWIFT-USB adapter to communicate with wireless devices that are not joined in a network, or with one or more wireless gateways and all devices that have formed a network with each gateway. A graphic representation of the wireless network provides important system data in an effective format, including communication links, signal strength, battery voltage and more.

Tool-less operation is supported, allowing you to perform site evaluation and system configuration and installation can be accomplished without using SWIFT Tools when necessary.

Multi-coloured LEDs on SWIFT devices provide feedback for interactions. At any point, only one instance of SWIFT Tools can run on a laptop or PC.

SWIFT Tools has the following utilities:

- ✓ Site Survey
- ✓ Create Mesh Network
- ✓ Diagnostics


SWIFT Tools works in a wireless environment with the SWIFT-GW, and devices within a range of approximately 6 meters. SWIFT Tools is designed for systems running Microsoft Windows.

#### MINIMUM SYSTEM REQUIREMENTS

**Operating System:** Windows XP Professional (SP3), Vista, Windows 7, Windows 8 and Windows 10 (32bit/64bit). **Hard Drive:** 20GB hard drive space with minimum 1GB free space on hard disk.

RAM: Minimum 512MB RAM

Processor Speed: 1GHz minimum (2.4 GHz recommended) Processor, 512K Cache



Example of SWIFT Tools' Diagnostic Utility

NSW 18-20 Brookhollow Ave NORWEST 2153 02 8850 2888 sales@firesense.com.au VIC Unit 4, 297 Ingles St PORT MELBOURNE 3207 03 9646 4557 salesvic@firesense.com.au





# SWIFT COMPONENTS & ORDERING INFORMATION


| SWIFT-GW                      | FlashScan Wireless SWIFT Gateway – 1 SWIFT Gateway is required for each wireless<br>mesh, and supports up to 49 SWIFT detectors or modules. Connects to the SLC loop<br>of a compatible panel using FlashScan protocol. Power may be supplied by the SLC<br>circuit or via an optional 24Vdc input.<br>Note: Use of the 24Vdc input may be more convenient for service as it allows for<br>powering down a gateway without shutting down an SLC loop.                                   |
|-------------------------------|---|
| SWIFT-P                       | FlashScan intelligent, wireless photo detector. Requires one SWIFT-BASE for installation. Requires (4) CR-123A batteries (included).  |
| SWIFT-Acclimate               | FlashScan intelligent wireless Acclimate heat and photo detector, using combined heat and smoke sensor information and the ability to automatically adjust sensitivity, based on ambient changes in the environment. Requires one SWIFT-BASE for installation. Requires (4) CR-123A batteries (included).   |
| SWIFT-H-57C                   | FlashScan intelligent wireless fixed-temperature 57 °C heat detector. Requires one SWIFT-BASE for installation. Requires (4) CR-123A batteries (included).  |
| SWIFT-MM                      | FlashScan wireless monitor module. Used to monitor devices with mechanical contact actuation. Includes a special cover with a tamper magnet built in. Recommended for installation in a SMB500 box (ordered separately) rather than a metal blackbox for best performance. Ships with 4 Panasonic CR123A or 4 Duracell DL123A batteries. (See data sheet for more information).   |
| SWIFT-BASE                    | Detector base used for wireless detectors. Includes a built-in magnet so that wireless devices can establish installed and tampered states.   |
| FireSense Website<br>Download | SWIFT Tools programming and diagnostic utility. Free download from www.firesense.com.au. For installation on a PC running an approved version of Windows (See minimum system requirements for SWIFT Tools). Requires the W-USBAUS radio/antenna dongle for communication with SWIFT Wireless devices. <i>Note:</i> SWIFT Tools is intended for use with NOTIFIER branded products. It will not work with other brands.  |
| SWIFT-USB                     | Wireless USB radio/antenna dongle that plugs into the USP port of a PC running SWIFT Tools. The SWIFT-USB provides a communication link with SWIFT Wireless devices that are within approximately 6 meters and have not formed a mesh. Alternately, when the devices have formed a mesh, bringing the PC/SWIFT-USB within range (6m) of the gateway for that mesh, will allow SWIFT Tools to acquire information on all devices in that mesh, including point-to-point signal strength. |





PRODUCT DATA SHEET SWIFT-GW Wireless Gateway

### SWIFT NETWORK



# AGENCY LISTINGS & APPROVALS

These listing and approvals apply to the modules specified in this document. In some cases, certain modules or applications may not be listed by certain approval agencies, or listing may be in process. Consult system consultant for latest listing status.

- ✓ AS ISO 7240.25:2015
- ✓ AS ISO 7240.18:2015
- ✓ AS ISO 7240.17:2015\*
- ✓ AS 7240.5-2004
- ✓ AS 7240.7-2004

\*=Compliant with ACMA Radiocommunications Class 2000 and Class 2002 National Rules.

NSW 18-20 Brookhollow Ave NORWEST 2153 02 8850 2888 sales@firesense.com.au VIC Unit 4, 297 Ingles St PORT MELBOURNE 3207 03 9646 4557 salesvic@firesense.com.au

