

## **PRODUCT DATA SHEET**

## INT-IR2 IR<sup>2</sup> Flame Detector

#### FEATURES

- ✓ High immunity to false sources
- Tolerant of fumes, vapours, dust and mist
- ✓ Suitable for indoor areas
- Unaffected by convection currents, draughts or wind
- ✓ Proven response to multiple fuel types
- ✓ Multi-spectrum detection
- ✓ Selectable output options
- ✓ Selectable response speed
- ✓ Selectable sensitivity levels
- ✓ Built in auto and manual test
- ✓ Low current consumption
- ✓ Fast response to fire



#### PRODUCT DESCRIPTION

The dual Infra-Red (IR<sup>2</sup>) Flame Detector is designed to protect areas where open fires may be expected and detects almost all flames, including hydrocarbon fires with 4.3 µm emissions through to invisible fires such as hydrogen.

The IR<sup>2</sup> Flame Detector is sensitive to flickering, low frequency (1-15Hz) infra-red radiation emitted by flames during combustion even if the lens is contaminated by a layer of oil, dust, water, vapour or ice.

This detector has two IR sensors which respond to different IR wavelengths in order to discriminate between flames and spurious sources of radiation. False alarms from flickering sunlight are avoided by a combination of filters and signal processing techniques.

The IR<sup>2</sup> detector has selectable output options of relay contacts or 4-20mA signal, as standard.

Note: This is an indent item, lead times of up to 4-6 weeks may apply.

#### **APPLICATIONS**

- ✓ Chemical plants
- ✓ Waste recycling
- ✓ Nuclear power sites
- ✓ Engine rooms
- Pharmaceutical production
- ✓ Military applications

- ✓ Printing
- ✓ Spray booths
- ✓ Coal handling
- ✓ Compressor stations
- ✓ Marine industry
- Tunnels

QLD Unit 2, 225 Queensport Rd North MURARRIE 4172 07 3890 8842 salesqld@firesense.com.au





# INT-IR2 IR<sup>2</sup> Flame Detector

### **TECHNICAL SPECIFICATIONS**

#### MECHANICAL

Housing material	Die Cast Zinc Alloy (ZA12)		
Housing colour	Blue		
Dimensions	142mm H x 108mm W x 82mm D		
Weight	2kg		
Cable Gland Entries	2 x 20mm		
Wiring	1.0 to 4.0mm <sup>2</sup>		

#### ELECTRICAL

Sensor supply	14 to 30Vdc		
Quiescent current	8mA, RL2 energised 4mA, current loop, RL2 off 3mA, RL2 off		
Alarm current	28mA, RL1 & RL2 energised 20mA, current loop, RL1 & 2 off 9mA, RL1 energised		
Power up time	2 seconds max		
Test signal voltage	14 to 30Vdc		
Ratings: current Voltage	Normally open or normally closed. Latching or non-latching 1.0A max. 50Vdc max. 30W max. (Note: resistive loads only)		

#### PERFORMANCE

•	0.1m <sup>2</sup> n-heptane at 25m 0.1m <sup>2</sup> n-heptane at 12m			
	(see EN54:10 for sensitivity settings)			
Field of View	90° min. cone			
Operating wavelength band - IR	0.75 to 2.7µm			

### ENVIRONMENTAL

Operating temperature	-10°C to +55°C
Storage temperature	-20°C to +65°C
Relative humidity	95% non-condensing
IP rating	IP66

VIC Unit 4, 297 Ingles St PORT MELBOURNE 3207 03 9646 4557 salesvic@firesense.com.au QLD Unit 2, 225 Queensport Rd North MURARRIE 4172 07 3890 8842 salesqld@firesense.com.au





### **PRODUCT DATA SHEET**

# INT-IR2 IR<sup>2</sup> Flame Detector

#### **RESPONSE CHARACTERISTICS - HIGH SENSITIVITY**


Fuel	Flame Size (m)	Certified distance (m)	Average response time (sec.)
n-Heptane (yellow flame)	0.3 x 0.3	25	12
Methylated spirit (clear flame)	0.5 x 0.5	25	25
Hydrogen (non-visible flame)	0.1 x 0.5	12	8

#### ACCESSORIES

- ✓ **INT-AM:** Adjustable mount (required for all flame detectors)
- ✓ **INT-DET-TESTER:** Portable flame detector testing unit

### **APPROVALS**


- ✓ CPR 0832-CPR-F0582
- ✓ LPCB 1204a/10
- ✓ AFNOR LIR 009 A2
- ✓ SIL 2 C127\_CT003\_(2.0)




To meet the requirements of EN54:10 clause 5.4, where the ratio of the response points Dmax: Dmin should not exceed 1.41, the horizontal and vertical viewing angles max should not exceed  $\pm 30^{\circ}$ .

#### Flame Detector

#### **Mounting Bracket**





VIC Unit 4, 297 Ingles St PORT MELBOURNE 3207 03 9646 4557 salesvic@firesense.com.au QLD Unit 2, 225 Queensport Rd North MURARRIE 4172 07 3890 8842 salesqld@firesense.com.au

