



15-01-2019

Ref #: 18-016

## Discontinuation Notice: HS-GW-EMPCA

To maintain up-to-date cybersecurity measures, Notifier will end support of the HS-GW-EMPCA (Embedded PC, Version A) hardware effective immediately.

The products listed below with a Board Type labelled "HS-GW-EMPCA" offered between 2009 – 2012, are affected:

- BACNET-GW-3
- CAP-GW
- LEDSIGN-GW
- MODBUS-GW
- NFN-GW-EM-3
- VESDA-VLI-GW
- NWS-3

For system upgrades performed after March 21<sup>st</sup>, 2018, it will be necessary to replace HS-GW-EMPCA hardware with current HS-GW-EMPCB (Embedded PC, Version B) hardware for the products listed above.

Yours Sincerely,

Robert Kaslik

General Manager

		NSW Head Office	Victoria Branch	Queensland Branch
FireSense Pty Ltd ATF FireSense Trust  ABN: 11 720 788 915  <a href="http://www.firesense.com.au">www.firesense.com.au</a>	Postal Address:  PO Box 7026 Baulkham Hills BC NSW 2153 Australia	18-20 Brookhollow Ave Baulkham Hills NSW 2153  Ph: (02) 8850 2888 Fax: (02) 8850 2999	4/297 Ingles St Port Melbourne VIC 3207  Ph: (03) 9646 4557 Fax: (03) 9646 4558	2/225 Queensport Rd Nth Murarrie QLD 4172  Ph: (07) 3890 8842 Fax: (07) 3890 8894