

FEATURES

- ✓ Provides VESDAnet fault-tolerant communication
- ✓ Quick and simple to install
- ✓ Minimal configuration required before operation
- ✓ Diagnostic LEDs give visual indication of the card's status
- ✓ Fully transferrable between VLF detectors
- ✓ Includes interface card, interface cables, screws and VESDAnet cable connectors



PRODUCT DESCRIPTION

The VESDAnet™ Interface Card (VN Card) is a simple interface card for the range of VESDA VLF smoke detectors. The VN Card provides VESDAnet communication from the detector to other VESDAnet devices, including configuration and monitoring tools.

What is VESDAnet?

VESDAnet is a fault-tolerant proprietary VESDA communications protocol. VESDAnet allows the VESDA range of smoke detectors, displays, programmers and remote units to communicate with each other on one network.

Why connect to VESDAnet?

Installing a VESDAnet Interface Card into a VLF detector and connecting to a VESDAnet offers many benefits, including:

Central, convenient communications with VESDA detectors

VESDAnet allows configuration, monitoring and control from local or remote sites. A technician can communicate with all detectors on the network from a central location using a PC rather than connecting to each smoke detector individually.

Remote displays and relays for the VLF detector


By installing a VN Card in a VLF detector, remote displays and remote relays can be added to the VLF. This extends the capability and flexibility of the VLF detector.

Connecting VESDA detectors to building management systems or fire panels

Using an appropriate High Level Interface (HLI), the information on VESDAnet can be transmitted to 3rd party monitoring and control systems such as Building Management Systems (BMS) and Fire Alarm Control Panels (FACP).

Preventing nuisance alarms due to outside air pollution

The VLF can be used as a cost effective reference detector for other active detectors on a VESDAnet. Referencing is a technique used to reduce the risk of unwanted alarms caused by external influences to a building, such as air pollution. It works by offsetting the signal from the active detector in the protected area with a reference signal from a detector monitoring the fresh air intake to the area. This results in the active detector measuring changes in smoke levels that are due only to events in the protected area, rather than those external to the area.



Having all VESDA smoke detectors on a VESDAnet loop allows you to configure and interrogate each detector from a central location, in this case the Facility Manager's office.

COMPATIBILITY

Individual VLF detectors can be interrogated and configured by Xtralis VSC, through their onboard serial interface. However, it is not possible to access other detectors on VESDAnet through this serial port.

To configure devices via VESDAnet, an High Level Interface (HLI) must be connected to a VESDAnet socket. This socket is available on VLP, VLS and VLC-505 detectors. Alternatively, a remote VESDAnet socket module (VRT-300) provides direct connectivity to an HLI or a hand held programmer.

A hand-held programmer or High Level Interface (HLI) module cannot be directly connected to a VLF detector.

TECHNICAL SPECIFICATIONS

Power Consumption	Consumes less than 1W from the detector at 24Vdc & 42mA	
Dimensions	137mm L x 71mm W x 20mm H	
Weight	0.08kg	
Terminals	0.2-2.5mm ² (30 - 12 AWG)	
Operating Conditions	Tested to:	-10 to 55°C
	Detector Ambient:	0 to 40°C
	Humidity:	5% to 95% (non-condensing)

APPROVALS

- ✓ UL
- ✓ ULC
- ✓ ActivFire certified
- ✓ EN 54-20