FireSense
FIRE ALARM EQUIPMENT

DATA SHEET
2600
8 – 64 Zone Fire Alarm Panel



Features:

- Expandable from 8 to 64 zones
- Up to 64 Programmable relay outputs
- Walk test, Site Programmable via keypad
- Optional Laptop programming utility
- LCD Display, ASE Facilities
- Individual Alarm, Fault, Isolate indicators
- Printer port
- Optional OWS amplifiers from 10 to 250 watt
- Time delay zones for AS 1668 fan controls
- Alarm Verification Facility

Description:

The IFS-2600 Fire Indicator Panel has been designed using complex microprocessor technology whilst maintaining simplicity of use. The panel may be configured using either the on-board keypad or a laptop computer. The combination of an LCD screen and LED indicators provide clear indication of system status including time and date. Up to 64 fully programmable relay outputs can be added to the system and OWS (Occupant warning system) amplifiers can be added from 10watt through to 250Watt.

Specifications:

Cabinet:	Zinc sealed steel, Powder coated (Charcoal) 003 Key-lock
AC Operational Voltage:	240 VAC 50 Hz±10%
Battery Charger:	27.3 VDC 1.5 Amp
Panel Supply:	24.5 VDC 3.0 Amp
Memory Type:	Non-volatile E 2ROM
Operating Humidity Range:	+40 º at 93% Relative humidity, non-condensing
Operating Temperature Range:	-10 º to +55ºC Dry heat

Outside Dimensions:

Panel (8 zones):	440mm H x 390mm W x 160mm D
Panel (16-24 zones):	750mm H x 390mm W x 160mm D
Panel (24+ zones):	Custom build, please call to confirm
Battery Box:	280mm H x 390mm W x 160mm D

Outputs:

Standby Relay:	C, NO, NC
Brigade Relay 1(Programmable):	C, NO, NC
Brigade Relay 2(Programmable):	C, NO, NC
Fault Relay:	C, NO, NC
Mains Fail Relay:	C, NO, NC
Isolate Relay:	C, NO, NC
General Alarm Relay (x2):	C, NO, NC
Warning System Output:	24VDC 1A Monitored 4k7EOL
Bell Output:	24VDC 1A Monitored 4k7EOL
ACF Output:	24VDC 1A Monitored 4k7EOL
AUX Power Output:	24VDC 1A Fused
Door Holder Power Output:	24VDC 3A Fused (Requires Optional DHTX)

NSW (Head Office)
18-20 Brookhollow Ave
Baulkham Hills NSW 2153
Tel 02 8850 2888
Fax 02 8850 2999
www.firesense.com.au

VIC (Branch Office)
4/297 Ingles St
Port Melbourne VIC 3207
Tel 03 9646 4557
Fax 03 9646 4558

QLD (Branch Office)
2/225 Queensport Rd Nth
Murarrie QLD 4172
Tel 07 3890 8842
Fax 07 3890 8894

DATA SHEET
2600
8 – 64 Zone Fire Alarm Panel

Approvals:

SSL Approved to AS 4428.1	**ActivFire Listing No.**	afp-1802

NSW (Head Office)
18-20 Brookhollow Ave
Baulkham Hills NSW 2153
Tel 02 8850 2888
Fax 02 8850 2999
www.firesense.com.au

VIC (Branch Office)
4/297 Ingles St
Port Melbourne VIC 3207
Tel 03 9646 4557
Fax 03 9646 4558

QLD (Branch Office)
2/225 Queensport Rd Nth
Murarrie QLD 4172
Tel 07 3890 8842
Fax 07 3890 8894