**FireSense**
FIRE ALARM EQUIPMENT

Features:

- 4 Stereo RCA line inputs (internally mono mixed).
- Individual bass, treble and volume controls
- 8 Balanced 3 pin XLR line outputs.
- Individual volume controls of all 8 outputs.
- Pre chime tone generator included
- Programmable labelling of input sources and output zones via USB keyboard.
- 240V AC or 24V DC operation.
- 19" Rack Mount (2 unit).

Description:

The FS-ALT-4480 is designed to meet the demands of today's complex installations. This is a very versatile, cost effective, PA/BGM control system and is suitable for clubs, pubs, gyms, campus sites, etc. In total there are 14 inputs – including, 1 zone paging & emergency paging input, 8 local inputs and 4 auxiliary inputs.

Specifications:

Auxiliary Inputs	Dual RCAs 0.3/0.7V
Local Inputs	RJ45
Outputs	3 pin XLR balanced line
Dimensions	482W x 152D x 88H mm

NOTIFIER by Honeywell

SYSTEM SENSOR

xtralis VESDA

zonecheck

bellcheck
THE AUTOMATIC ALARM VALVE TEST SYSTEM

livetap
UNDER PRESSURE DRILLING

NSW (Head Office)	VIC (Branch Office)	QLD (Branch Office)
18-20 Brookhollow Ave	4/297 Ingles St	2/225 Queensport Rd Nth
Baulkham Hills NSW 2153	Port Melbourne VIC 3207	Murarrie QLD 4172
Tel 02 8850 2888	Tel 03 9646 4557	Tel 07 3890 8842
Fax 02 8850 2999	Fax 03 9646 4558	Fax 07 3890 8894
www.firesense.com.au		

Accessories:

Optional Mic: (FS-4470-MIC)

Designed specifically for use with the FS-ALT-4470 audio switcher, the addition of this microphone enables local paging to any zone or combination of zones. Paging to any any zone may be inhibited by selecting the paging on/off function for individual zones on the FS-ALT-4470. The paging microphone may be located up to 300 metres from the FS-ALT-4470 and all audio and control signals are carried via an inexpensive Cat 5 or similar data cable.

NSW (Head Office)	VIC (Branch Office)	QLD (Branch Office)
18-20 Brookhollow Ave	4/297 Ingles St	2/225 Queensport Rd Nth
Baulkham Hills NSW 2153	Port Melbourne VIC 3207	Murarrie QLD 4172
Tel 02 8850 2888	Tel 03 9646 4557	Tel 07 3890 8842
Fax 02 8850 2999	Fax 03 9646 4558	Fax 07 3890 8894
www.firesense.com.au		

G:\Documents\Datasheets\Word Datasheets\FS-ALT-A4585 (2).Doc   RevDate: 20 September 2017