



ULTRAVIOLET STABILISATION

FireSense Fire Rated & LSZH Cable Range

As part of the construction of the FireSense Fire Rated Cables & LSZH Earth Cables, the outer sheath is constructed with a Halogen Free cross linked polymer (HFS-110-TP) that is UV stabilised.

The construction properties of the Fire Rated cable range are in accordance with the following standards:

- AS/NZS5000.1
- AS/NZS3808
- AS/NZS3013

The cables have also been approved by a Third Party Testing Authority.

For any further enquiries/questions, please feel free to contact myself or your closest branch.

Robert Kaslik
Managing Director

		NSW Head Office	Victoria Branch	Queensland Branch
FireSense Pty Ltd ATF FireSense Trust	Postal Address:	18-20 Brookhollow Ave Baulkham Hills NSW 2153	4/297 Ingles St Port Melbourne VIC 3207	2/225 Queensport Rd Nth Murarrie QLD 4172
ABN: 11 720 788 915	PO Box 7026 Baulkham Hills BC NSW 2153 Australia	Ph: (02) 8850 2888 Fax: (02) 8850 2999	Ph: (03) 9646 4557 Fax: (03) 9646 4558	Ph: (07) 3890 8842 Fax: (07) 3890 8894
www.firesense.com.au				